

SVGW

Association  
for water, gas and district heating  
Grütlistrasse 44  
CH- 8027 Zürich

Certification body water



**Certificate No.: 2311-7259**

**Certificate holder:** FOX Fittings Sp. z o.o. Sp. k., Wiezniów Oswiecimia 50, PL-43330 Wilamowice

In accordance with our regulation ZW101 „general terms and conditions of the SVGW certification body water“ the SVGW certify the following serial products:

**Rubric:** Compression fittings for PE pipes (laid in the ground)  
**Denomination:** FOX PE/brass transition adapter  
**Types:** d32-d110 PE/brass transition adapter with female thread PN 16  
d32-d110 PE/brass transition adapter with male thread PN 16

DN: 32...110 PN: 16 tmax: 25 °C

**Certification Standard:** In accordance with SVGW ZW157 (01/19)

**Validity:** 30.11.2028

**Conditions (C) / Remarks (R):**

(A) According to ZGW101 (01/19), Annex A, the minimum wall thickness for fittings is 3.0 mm and for pipes 2.9 mm.

The applicant is entitled to offer the above mentioned products as certificated by the SVGW and to use the above SVGW-conformity mark (publication in the list of certificates water).

SVGW Association for water, gas and district heating

Certification body water

Javier Fernandez

Head

Zurich, 28.02.2024

**Rubric:** Compression fittings for PE pipes (laid in the ground)

**Denomination:** FOX PE/brass transition adapter

Types	DN	PN	C°	Acoustic group	Losses kWh/24 h / ErP Class	Content	Index	Metrology
PE/Messing Übergangsadapter mit Innengewinde PN 16;	32...110	16	25	-	-	-	-	-
PE/Messing Übergangsadapter mit Aussengewinde PN 16	32...110	16	25	-	-	-	-	-